

Tetrachloroethene (PCE) concentrations detected in samples from the New Haven Water Distribution System and Wells collected by the Missouri Department of Natural Resources between 1987 and 1993. All concentrations in micrograms per liter (mg/L).

[<, less than the analytical method detection limit]

Sample Date	WELL SAMPLE LOCATIONS (µg/L)					DISTRIBUTION SAMPLE LOCATIONS (µg/L)								
	Well #1	Well #2	Well #3	ARP Well	Pepsi Well	City Hall	City Firehouse	City Shed	Circle Drive	Locust St.	E. Bates St.	E. Industrial Dr.	Mary Hammack St.	Hwy 100
06/30/86	3.6	28.2												
12/22/86	21	89												
02/10/87	5.9	52				6.5	77							
03/06/87	<5	40				5			47					
05/22/87	<5	58				5.1			42	15	30	33		16
02/26/88		26												
05/17/88	4.3	47	<0.2	<0.2	<0.2									
06/30/88			<0.2			7.4		54	3.7				2.1	
02/16/89	<5	89	<5			<5.0		48	<5.0					
03/30/89		47	<5					48						
12/12/89	2.4	62	<2											
06/11/90		47	<0.5					42						
07/25/90		62	<0.5					66						
05/15/91	1.8	95	<1											
04/13/93	2.3	89	<0.5											
09/22/93		140	<0.2					<0.2						

Blank space indicates sample not collected.